

**Dhr. Filip De Mulder**  
**IVC NV**  
**Nijverheidslaan 29**  
**8580 AVELGEM**

Your notice of

Your reference

our reference

date

PW/1831

2014-07-09

## Certification Report Nr. 14/1831

### 1. Description of the flooring:

Product group: Moduleo / Design Floors  
PVC floor covering  
Total mass: 3271 g/m<sup>2</sup> - 4059 g/m<sup>2</sup>  
Thickness: 2.0 mm – 2.5 mm  
Wear layer: 0.30 mm – 0.55 mm

### 2. Executed tests:

European Fire classification in accordance with EN 13501-1 (2002)		
Class	EN ISO 11925-2 (15 s surface flame attack) or EN 14041 (2004)	EN ISO 9239-1 (test duration = 30 min) heat flux ≥ 8.0 kW/m <sup>2</sup>
B <sub>fl</sub>	E <sub>fl</sub>	

### 3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

glued tested on a non-combustible substrate\*

**B<sub>fl</sub> - s1**

\* End use substrates of classes A1 or A2-s1, d0 (ISO 13238:2010 § 5.2.2)

This certification report runs to 2 pages and may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel.


The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples.

***Centexbel is recognized as notified body 0493 for the European Construction Products directive and the European directive for personal protective equipment***

**CENTEXBEL GENT**  
Technologiepark 7  
BE-9052 Zwijnaarde (Gent)  
Tel. +32 9 220 41 51  
Fax +32 9 220 49 55  
e-mail gent@centexbel.be

**CENTEXBEL BRUSSELS**  
Montoyerstraat 24-B2  
BE-1000 Brussels  
Tel. +32 2 287 08 30  
Fax +32 2 230 68 15  
e-mail brussel@centexbel.be

**CENTEXBEL VERVIERS**  
Avenue du Parc 38  
BE-4650 Herve (Chainieux)  
Tel. +32 87 32 24 30  
Fax +32 87 34 05 18  
e-mail chainieux@centexbel.be



**Addressee**  
IVC NV

**our ref.**  
PW/1831

**date**  
2014-07-09

**page number**  
2

Related commercial names to this product group are:

PREMIER  
VISION  
ARTENS  
PRIMERO  
PRIMERO MG  
MODULEO SELECT  
HORIZON  
LEGACY  
ULTIMO  
MODULEO IMPRESS  
MODULEO IMPRESS MG  
MODULEO TRANSFORM  
MODULEO TRANSFORM MG

The obtained classification is based on the next test reports:

Centexbel: 11.83179.01 of 2012-01-13  
Centexbel: 12.02627.01 of 2012-08-02  
Centexbel: 12.02627.02 of 2012-08-02

Certificate valid until 2017-01-13

Petra Wittevrongel  
Product certifier